

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0075:154 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Fire-Lite Alarms, Inc., One Fire-Lite Place, Northford, CT 06472-1653
Contact: *Brian Reynolds (203) 484-1200 FAX (203) 484-7309

DESIGN: Model MS-5012 fire alarm control unit. Local, automatic, manual, sprinkler supervisory and waterflow alarm service, *central station, and *remote station. Suitable for stand-alone or slave application. Refer to listee's data sheet for additional detailed product description and operational considerations. System accessories:

ADM-12	Annunciator driver
RZA-5F	Remote Annunciator

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control unit for use with separately listed electrically and functionally compatible initiating and indicating devices. Refer to listee's Installation Instruction Manual for details.

*Rev. 06/09/03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 21, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**